

ENGINE SPEED:	1500	FUEL:	NAT GAS
COMPRESSION RATIO:	11.3:1	FUEL SYSTEM:	CAT LOW PRESSURE WITH AIR FUEL RATIO CONTROL
AFTERCOOLER - STAGE 1 MAX. INLET (°F):	180	FUEL PRESS. RANGE (PSIG):	0.50 - 5.0
AFTERCOOLER - STAGE 2 MAX. INLET (°F):	130	MIN. METHANE NUMBER:	80
JACKET WATER - MAX. OUTLET (°F):	194	RATED ALTITUDE (FT):	821
COOLING SYSTEM:	JW+OC+1AC, 2AC	AT AIR TO TURBO. TEMP. (°F):	77
IGNITION SYSTEM:	ADEM3	NOx EMISSION LEVEL:	0.5 g/bhp-hr
EXHAUST MANIFOLD:	DRY	FUEL LHV (BTU/SCF):	905
COMBUSTION:	LOW EMISSION	APPLICATION:	GENSET
EFFECTIVE SERIAL NUMBER:	GZN00215-Up		

RATING AND EFFICIENCY		NOTES	LOAD	100%	75%	50%
ENGINE POWER	(WITHOUT FAN)	(1)	BHP	2717	2038	1358
GENERATOR POWER	(WITHOUT FAN)	(2)	EKW	1950	1463	975
ENGINE EFFICIENCY	(ISO 3046/1)	(3)	%	39.6	38.5	36.4
ENGINE EFFICIENCY	(NOMINAL)	(3)	%	38.7	37.6	35.5
THERMAL EFFICIENCY	(NOMINAL)	(4)	%	41.5	42.3	43.9
TOTAL EFFICIENCY	(NOMINAL)	(5)	%	80.2	79.8	79.4

ENGINE DATA						
FUEL CONSUMPTION	(ISO 3046/1)	(6)	BTU/bhp-hr	6424	6615	6991
FUEL CONSUMPTION	(NOMINAL)	(6)	BTU/bhp-hr	6581	6776	7161
AIR FLOW (77 °F, 14.7 psi)		(7)	SCFM	5865	4476	3090
AIR FLOW		(7)	lb/hr	26003	19846	13700
COMPRESSOR OUT PRESSURE			in. HG (abs)	100.8	77.8	53.5
COMPRESSOR OUT TEMPERATURE			°F	377	304	217
AFTERCOOLER AIR OUT TEMPERATURE			°F	132	132	131
INLET MAN. PRESSURE		(8)	in. HG (abs)	92.1	70.5	49.2
INLET MAN. TEMPERATURE	(MEASURED IN PLENUM)	(9)	°F	133	133	133
TIMING		(10)	°BTDC	26	26	26
EXHAUST STACK TEMPERATURE		(11)	°F	856	900	947
EXHAUST GAS FLOW (@ stack temp.)		(12)	CFM	15451	12192	8720
EXHAUST MASS FLOW		(12)	lb/hr	26899	20538	14187

EMISSIONS DATA						
NOx (as NO2)		(13)	g/bhp-hr	0.5	0.5	0.5
CO		(14)	g/bhp-hr	2.17	2.15	2.14
THC (molecular weight of 15.84)		(14)	g/bhp-hr	6.48	7.24	7.9
NMHC (molecular weight of 15.84)		(14)	g/bhp-hr	0.98	1.09	1.19
CO2		(14)	g/bhp-hr	473	485	508
EXHAUST O2		(15)	% DRY	9.6	9.6	9.5
LAMBDA		(15)		1.80	1.78	1.74

HEAT BALANCE DATA						
LHV INPUT		(16)	BTU/min	297960	230106	162128
HEAT REJECTION TO JACKET		(17)	BTU/min	34240	29216	24139
HEAT REJECTION TO ATMOSPHERE		(18)	BTU/min	7098	5941	4784
HEAT REJECTION TO LUBE OIL		(19)	BTU/min	8584	7973	7082
HEAT REJECTION TO EXHAUST (LHV to 77 °F)		(20)	BTU/min	102372	83107	60908
HEAT REJECTION TO EXHAUST (LHV to 350 °F)		(20)	BTU/min	60545	50370	37947
HEAT REJECTION TO A/C - STAGE 1		(21)	BTU/min	20298	9715	1988
HEAT REJECTION TO A/C - STAGE 2		(22)	BTU/min	7649	5240	3117

CONDITIONS AND DEFINITIONS

ENGINE RATING OBTAINED AND PRESENTED IN ACCORDANCE WITH ISO 3046/1. DATA REPRESENTS CONDITIONS OF 77°F, 29.6 IN HG BAROMETRIC PRESSURE, 30% RELATIVE HUMIDITY, 10 IN H2O AIR FILTER RESTRICTION, AND 20 IN H2O EXHAUST STACK PRESSURE. ENGINE EFFICIENCY AND FUEL CONSUMPTION SPECIFICALLY NOTED AS ISO 3046/1 ARE REPRESENTED WITH 5 IN H2O AIR FILTER RESTRICTION AND 0 IN H2O EXHAUST STACK PRESSURE. CONSULT ALTITUDE CURVES FOR APPLICATIONS ABOVE MAXIMUM RATED ALTITUDE AND/OR TEMPERATURE. NO OVERLOAD PERMITTED AT RATING SHOWN.

EMISSION LEVELS ARE BASED ON THE ENGINE OPERATING AT STEADY STATE CONDITIONS AND ADJUSTED TO THE SPECIFIED NOx LEVEL AT 100% LOAD. EMISSION TOLERANCES SPECIFIED ARE DEPENDENT UPON FUEL QUALITY. METHANE NUMBER CANNOT VARY MORE THAN ± 3. PUBLISHED PART LOAD DATA IS WITH AIR FUEL RATIO CONTROL.

ENGINE RATING IS WITH 2 ENGINE DRIVEN WATER PUMPS. PUMP POWER IS NOT INCLUDED IN HEAT BALANCE DATA.

FOR NOTES INFORMATION CONSULT PAGE THREE.

FUEL USAGE GUIDE												
CAT METHANE NUMBER	30	35	40	45	50	55	60	65	70	75	80	85 to 100
IGNITION TIMING	-	-	-	-	-	16	16	16	16	19	26	26
DERATION FACTOR	0	0	0	0	0	0.73	0.82	0.90	0.98	1.00	1.00	1.00

ALTITUDE DERATION FACTORS															
AIR TO TURBO (°F)	130	0.94	0.90	0.87	0.84	0.81	0.78	0.75	0.72	0.69	0.66	0.64	0.61	0.59	
	120	0.95	0.92	0.89	0.85	0.82	0.79	0.76	0.73	0.70	0.68	0.65	0.62	0.60	
	110	0.97	0.94	0.90	0.87	0.84	0.80	0.77	0.74	0.71	0.69	0.66	0.63	0.61	
	100	0.99	0.95	0.92	0.88	0.85	0.82	0.79	0.76	0.73	0.70	0.67	0.65	0.62	
	90	1.00	0.97	0.93	0.90	0.87	0.83	0.80	0.77	0.74	0.71	0.68	0.66	0.63	
	80	1.00	0.99	0.95	0.92	0.88	0.85	0.82	0.79	0.75	0.73	0.70	0.67	0.64	
	70	1.00	1.00	0.97	0.93	0.90	0.86	0.83	0.80	0.77	0.74	0.71	0.68	0.65	
	60	1.00	1.00	0.99	0.95	0.92	0.88	0.85	0.82	0.78	0.75	0.72	0.69	0.67	
	50	1.00	1.00	1.00	0.97	0.93	0.90	0.86	0.83	0.80	0.77	0.74	0.71	0.68	
			0	1000	2000	3000	4000	5000	6000	7000	8000	9000	10000	11000	12000

ALTITUDE (FEET ABOVE SEA LEVEL)

AFTERCOOLER HEAT REJECTION FACTORS															
AIR TO TURBO (°F)	130	1.31	1.35	1.35	1.35	1.35	1.35	1.35	1.35	1.35	1.35	1.35	1.35	1.35	
	120	1.25	1.29	1.29	1.29	1.29	1.29	1.29	1.29	1.29	1.29	1.29	1.29	1.29	
	110	1.19	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	
	100	1.12	1.16	1.16	1.16	1.16	1.16	1.16	1.16	1.16	1.16	1.16	1.16	1.16	
	90	1.06	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	
	80	1.00	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	
	70	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	
	60	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	
	50	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	
			0	1000	2000	3000	4000	5000	6000	7000	8000	9000	10000	11000	12000

ALTITUDE (FEET ABOVE SEA LEVEL)

FUEL USAGE GUIDE:

This table shows the derate factor required for a given fuel. Note that deration occurs as the methane number decreases. Methane number is a scale to measure detonation characteristics of various fuels. The methane number of a fuel is determined by using the Caterpillar Methane Number Calculation program.

ALTITUDE DERATION FACTORS:

This table shows the deration required for various air inlet temperatures and altitudes. Use this information along with the fuel usage guide chart to help determine actual engine power for your site.

INLET AND EXHAUST RESTRICTION CORRECTIONS FOR ALTITUDE CAPABILITY:

To determine the appropriate altitude derate factor to be applied to this engine for inlet or exhaust restrictions differering from the standard conditions listed on page 1, a correction to the site altitude can be made to adjust for this difference. Add 139 feet to the site altitude for each additional inch of H2O of exhaust stack pressure greater than spec sheet conditions. Add 122 feet to the site altitude for each additional inch of H2O of inlet restriction greater than spec sheet conditions. If site inlet restriction or exhaust stack pressure are less than spec sheet conditions, the same trends apply to lower the site altitude.

ACTUAL ENGINE RATING:

It is important to note that the Altitude/Temperature deration and the Fuel Usage Guide deration are not cumulative. They are not to be added together. The same is true for the Low Energy Fuel deration (reference the Caterpillar Methane Number Program) and the Fuel Usage Guide deration. However, the Altitude/Temperature deration and Low Energy Fuel deration are cumulative; and they must be added together in the method shown below. To determine the actual power available, take the lowest rating between 1) and 2).

- 1) (Altitude/Temperature Deration) + (Low Energy Fuel Deration)
- 2) Fuel Usage Guide Deration

Note: For NA's always add the Low Energy Fuel deration to the Altitude/Temperature deration. For TA engines only add the Low Energy Fuel deration to the Altitude/Temperature deration whenever the Altitude/Temperature deration is less than 1.0 (100%). This will give the actual rating for the engine at the conditions specified.

AFTERCOOLER HEAT REJECTION FACTORS:

Aftercooler heat rejection is given for standard conditions of 77 °F and 500 ft altitude. To maintain a constant air inlet manifold temperature, as the air to turbo temperature goes up, so must the heat rejection. As altitude increases, the turbocharger must work harder to overcome the lower atmospheric pressure. This increases the amount of heat that must be removed from the inlet air by the aftercooler. Use the aftercooler heat rejection factor to adjust for ambient and altitude conditions. Multiply this factor by the standard aftercooler heat rejection. Failure to properly account for these factors could result in detonation and cause the engine to shutdown or fail. For 2 Stage Aftercoolers with separate circuits, the 1st stage will collect 90% of the additional heat.

SOUND DATA:

Sound Power Data can be found in DM8888.

NOTES

- 1 ENGINE RATING IS WITH 2 ENGINE DRIVEN WATER PUMPS. TOLERANCE IS $\pm 3\%$ OF FULL LOAD.
- 2 GENERATOR POWER DETERMINED WITH AN ASSUMED GENERATOR EFFICIENCY OF 96.25% AND POWER FACTOR OF 0.8 [GENERATOR POWER = ENGINE POWER x GENERATOR EFFICIENCY].
- 3 ISO 3046/1 ENGINE EFFICIENCY TOLERANCE IS (+)0, (-)5% OF FULL LOAD % EFFICIENCY VALUE. NOMINAL ENGINE EFFICIENCY TOLERANCE IS $\pm 2.5\%$ OF FULL LOAD % EFFICIENCY VALUE.
- 4 THERMAL EFFICIENCY: JACKET HEAT + LUBE OIL HEAT + STAGE 1 A/C HEAT + EXH. HEAT TO 350°F.
- 5 TOTAL EFFICIENCY = ENGINE EFF. + THERMAL EFF. TOLERANCE IS $\pm 10\%$ OF FULL LOAD DATA.
- 6 ISO 3046/1 FUEL CONSUMPTION TOLERANCE IS (+)5, (-)0% OF FULL LOAD DATA. NOMINAL FUEL CONSUMPTION TOLERANCE IS $\pm 2.5\%$ OF FULL LOAD DATA.
- 7 UNDRYED AIR. FLOW TOLERANCE IS $\pm 5\%$
- 8 INLET MANIFOLD PRESSURE TOLERANCE IS $\pm 5\%$
- 9 INLET MANIFOLD TEMPERATURE TOLERANCE IS $\pm 9^\circ\text{F}$.
- 10 TIMING INDICATED IS FOR USE WITH THE MINIMUM FUEL METHANE NUMBER SPECIFIED. CONSULT THE APPROPRIATE FUEL USAGE GUIDE FOR TIMING AT OTHER METHANE NUMBERS.
- 11 EXHAUST STACK TEMPERATURE TOLERANCE IS (+)63°F, (-)54°F.
- 12 WET EXHAUST. FLOW TOLERANCE IS $\pm 6\%$
- 13 NOX TOLERANCES ARE $\pm 18\%$ OF SPECIFIED VALUE.
- 14 CO, CO₂, THC, and NMHC VALUES ARE "NOT TO EXCEED".
- 15 O₂% TOLERANCE IS ± 0.5 ; LAMBDA TOLERANCE IS ± 0.05 . LAMBDA AND O₂ LEVEL ARE THE RESULT OF ADJUSTING THE ENGINE TO OPERATE AT THE SPECIFIED NOX LEVEL.
- 16 LHV RATE TOLERANCE IS $\pm 2.5\%$.
- 17 TOTAL JW HEAT (based on treated water) = JACKET HEAT + LUBE OIL HEAT + STAGE 1 A/C HEAT + 0.90 x (STAGE 1 + STAGE 2) x (ACHRF-1). TOLERANCE IS $\pm 10\%$ OF FULL LOAD DATA.
- 18 RADIATION HEAT RATE BASED ON TREATED WATER. TOLERANCE IS $\pm 50\%$ OF FULL LOAD DATA.
- 19 LUBE OIL HEAT RATE BASED ON TREATED WATER. TOLERANCE IS $\pm 20\%$ OF FULL LOAD DATA.
- 20 EXHAUST HEAT RATE BASED ON TREATED WATER. TOLERANCE IS $\pm 10\%$ OF FULL LOAD DATA.
- 21 STAGE 1 A/C HEAT (based on treated water) = STAGE 1 A/C HEAT + 0.90 x (STAGE 1 + STAGE 2) x (ACHRF-1). TOLERANCE IS $\pm 5\%$ OF FULL LOAD DATA.
- 22 STAGE 2 A/C HEAT (based on treated water) = STAGE 2 A/C HEAT + (STAGE 1 + STAGE 2) x 0.10 x (ACHRF - 1). TOLERANCE IS $\pm 5\%$ OF FULL LOAD DATA.